

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:36 pm

**PWS ID:** UTAH22012      **Name:** COMMUNITY WATER COMPANY  
**Legal Contact:** COMMUNITY WATER COMPANY      **Rating:** Approved  
FRAN AMENDOLA      **Rating Date:** 06/14/1992  
**Address:** 4000 CANYONS RST DR      **Activity Status:** Active  
PARK CITY, UT 84098  
**Phone Number:** 435-557-3127  
**City Served (Area):**  
**County:** SUMMIT COUNTY

**System Type:** Community      **Last Inv Update:** 01/24/2011      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 10/27/2009      **Total Dsgn Cap:**  
**Population:** 500      **Surveyor:** JULIE COBLEIGH      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

**Gal/Day   Gal/Min**

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	AMENDOLA, FRAN	VP ENV AFFAIR	801-539-0044		FAMENDOLA@NORWEST.UT

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered/Unmetered	0	506
			506 Total Svc Connections

### Storage

**Total Storage:** 657,000 GAL      **Number of Units:** 2      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	417,000 GAL	Steel		A	NO
ST002	STORAGE FACILITY ST002	Ground	240,000 GAL	Steel		A	NO

### Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	WILLOWCREEK WTP		A	

### Distribution System

Pump Type	Total Dyn Head		Pressure Adequate	Cross Connection	Authority Statement
	ft H2O	P.S.I.			
No					

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001A	THIRIOT SPRING	Inactive	IN				Yes	SW	Permanent		
WS002	WAGON TRAIL #2 WELL	Active	WL	6	16 GPM	30 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	AMBUSH #1 WELL	Inactive	WL	8	40 GPM		Yes	GW	Permanent		
WS004	AMBUSH #2 WELL	Inactive	WL		25 GPM		Yes	GW	Permanent		
WS005	WAGON TRAIL #1 WELL	Inactive	WL				Yes	GW	Permanent		

\*Reports measured flow for wells, approved design capacity for all other sources.

---

## Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS006	GULCH NO 1 WELL	Active	WL	8	150 GPM	90 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS007	BUSHWACKER WELL	Inactive	WL				Yes	GW	Permanent		
WS008	UTAH22059 SUMMIT WATEF	Active	CC				No	SW	Permanent	1/1 to 12/31	

*\*Reports measured flow for wells, approved design capacity for all other sources.*